

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (0999)		7 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		
Total Coliform (3100)		7 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		2 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
126 PWDR MILL RD,CAN (5054)	10/1/18 - 12/31/18	10/1-10/31	Complete
	1/1/19 - 3/31/19	1/1-1/31	Complete
	4/1/19 - 6/30/19	4/1-4/30	
	7/1/19 - 9/30/19	7/1-7/31	
133 RIVER RD, COLL (5058)	10/1/18 - 12/31/18	10/1-10/31	Complete
	1/1/19 - 3/31/19	1/1-1/31	Complete
	4/1/19 - 6/30/19	4/1-4/30	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		2 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/19 - 9/30/19	7/1-7/31	
Lead And Copper (PBCU)		20 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	
Physical Parameters (PPS)		7 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **ENTRY POINT-FILTER PLANT (WSF ID: 00700)**

Net Gross Alpha (4000)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/17 - 12/31/25		Complete
Uranium (4006)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/17 - 12/31/25		Complete
Combined Radium-226/228 (4010)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/17 - 12/31/25		Complete
Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/18 - 12/31/18		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Monitoring Requirements

Water System Facility: ENTRY POINT-FILTER PLANT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: COLLINSVILLE WTP (WSF ID: 114)

Total Organic Carbon (2920)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
COMBINED FILTER EFFLUENT - COLLINSVILLE (5)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19		Complete	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: MDC NEPAUG RESERVOIR (WSF ID: 2129)

Total Alkalinity (1927)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
NEPAUG RESERVOIR (1)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19		Complete	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Monitoring Requirements

Water System Facility: MDC NEPAUG RESERVOIR (WSF ID: 2129)

Total Alkalinity (1927)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEPAUG RESERVOIR (1)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEPAUG RESERVOIR (1)	10/1/18 - 12/31/18		
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEPAUG RESERVOIR (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEPAUG RESERVOIR (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEPAUG RESERVOIR (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Monitoring Requirements

Water System Facility: MDC NEPAUG RESERVOIR (WSF ID: 2129)

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/20		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT-FILTER PLANT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.90 MG/L	2
Start Date: 9/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 1.10 MG/L	2
Start Date: 9/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 9/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Water System Facility: ENTRY POINT-FILTER PLANT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 7.5 PH	Daily
Start Date: 1/1/2004			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
11/1/2018 - 11/30/2018		N	
12/1/2018 - 12/31/2018		N	
1/1/2019 - 1/31/2019		N	
2/1/2019 - 2/28/2019		N	
3/1/2019 - 3/31/2019			
4/1/2019 - 4/30/2019			

Water System Facility: COLLINSVILLE WTP (WSFID: 114)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
11/1/2018 - 11/30/2018	Y	Y	
12/1/2018 - 12/31/2018	Y	Y	
1/1/2019 - 1/31/2019	Y	Y	
2/1/2019 - 2/28/2019	Y	Y	
3/1/2019 - 3/31/2019	Y	Y	
4/1/2019 - 4/30/2019			

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2004			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
11/1/2018 - 11/30/2018	Y	Y	
12/1/2018 - 12/31/2018	Y	Y	
1/1/2019 - 1/31/2019	Y	Y	
2/1/2019 - 2/28/2019	Y	Y	
3/1/2019 - 3/31/2019	Y	Y	
4/1/2019 - 4/30/2019			

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2005			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
11/1/2018 - 11/30/2018	Y	Y	
12/1/2018 - 12/31/2018	Y	Y	
1/1/2019 - 1/31/2019	Y	Y	
2/1/2019 - 2/28/2019	Y	Y	
3/1/2019 - 3/31/2019	Y	Y	
4/1/2019 - 4/30/2019			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
Total Coliform M&R Violation	1/1/11 - 3/31/11	3	6/13/2012		6/23/2012	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		5050	113 HCKLBRY HIL COL	A	Y			
		5051	104 MAIN ST CANTON	A	Y			
		5053	103 DEEPWOOD DR.	A	Y	3		
		5054	126 PWDR MILL RD,CAN	A	Y			Y
		5055	CANTON COMMONS,RT44	A	Y			
		5056	7 CEMETARY RD, COL	A	Y	3		
		5057	178 KINGSWOOD DR,COL	A	Y			
		5058	133 RIVER RD, COLL	A				Y
		50801	5 BRKVIEW CRCL,CAN	A		N		
		50802	3 WHIRLING DUN COL	A		2		
		50803	9 WHIRLING DUN COL	A		2		
		50804	23 WICKHAMS FANCY	A		2		
		50805	37 WICKHAMS FANCY	A		2		
		50806	39 WICKHAMS FANCY	A		2		
		50807	44 WICKHAMS FANCY	A		2		
		50808	3 BROOKVIEW CIR,CAN	A		N		
		50809	6 BROOKVIEW CIR, CAN	A		N		
		50810	18 BROOKVIEW CIR,CAN	A		N		
		50811	14 WICKHAMS FANCY	A		2		
		50812	29 WICKHAMS FANCY	A		2		
		50813	33 WICKHAMS FANCY	A		2		
		50814	35 WICKHAMS FANCY	A		2		
		50815	50 WICKHAMS FANCY	A		2		
		50816	52 WICKHAMS FANCY	A		2		
		50817	59 WICKHAMS FANCY	A		2		
		50818	62 WICKHAMS FANCY	A		2		
		50819	1 WHIRLING DUN COL	A		2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		50820	4 CAMILLE LN	A		N		
		50821	9 CAMILLE LN	A		N		
		50822	100 WINTERBOURNE LN	A		N		
		50823	116 WINTERBOURNE LN	A		N		
		50824	118 WINTERBOURNE LN	A		N		
		50825	126 WINTERBOURNE LN	A		N		
		50826	66 NEW RD, AV	A		1		
		50827	68 VERVILLE RD, AV	A		1		
		50828	55 ARCH ST, BLGTN	A		1		
		50829	15 BIRCH RD, CAN	A		1		
		50830	171 HL ST, CAN	A		1		
		50831	26 SECRET LAKE, CAN	A		1		
		50832	28 SECRET LAKE, CAN	A		1		
		50833	69 DYER AVE, COLL	A		1		
		50834	13 GLDRSLV AV, COLL	A		1		
		50835	83 SIMONDS AVE, COLL	A		1		
		50836	75 TRNGTN AV, COLL	A		1		
		50837	45 ARCH ST, BLGTN	A		2		
		50838	61 ARCH ST, BLGTN	A		2		
		50839	1 WCKHMS FNCY, CAN	A		2		
		50840	2 WCKHMS FNCY, CAN	A		2		
		50841	3 WCKHMS FNCY, CAN	A		2		
		50842	4 WCKHMS FNCY, CAN	A		2		
		50843	5 WCKHMS FNCY, CAN	A		2		
		50844	6 WCKHMS FNCY, CAN	A		2		
		50845	7 WCKHMS FNCY, CAN	A		2		
		50846	CTWC - NAUG-COL	A	Y			
		50847	9 WCKHMS FNCY, CAN	A		2		
		50848	10 WCKHMS FNCY, CAN	A		2		
		50849	11 WCKHMS FNCY, CAN	A		2		
		50850	12 WCKHMS FNCY, CAN	A		2		
		50851	13 WCKHMS FNCY, CAN	A		2		
		50852	15 WCKHMS FNCY, CAN	A		2		
		50853	16 WCKHMS FNCY, CAN	A		2		
		50854	17 WCKHMS FNCY, CAN	A		2		
		50855	19 WCKHMS FNCY, CAN	A		2		
		50856	20 WCKHMS FNCY, CAN	A		2		
		50857	21 WCKHMS FNCY, CAN	A		2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		50858	22 WCKHMS FNCY, CAN	A		2		
		50859	24 WCKHMS FNCY, CAN	A		2		
		50860	25 WCKHMS FNCY, CAN	A		2		
		50861	26 WCKHMS FNCY, CAN	A		2		
		50862	27 WCKHMS FNCY, CAN	A		2		
		50863	28 WCKHMS FNCY, CAN	A		2		
		50864	30 WCKHMS FNCY, CAN	A		2		
		50865	31 WCKHMS FNCY, CAN	A		2		
		50866	32 WCKHMS FNCY, CAN	A		2		
		50867	34 WCKHMS FNCY, CAN	A		2		
		50868	36 WCKHMS FNCY, CAN	A		2		
		50869	38 WCKHMS FNCY, CAN	A		2		
		50870	40 WCKHMS FNCY, CAN	A		2		
		50871	41 WCKHMS FNCY, CAN	A		2		
		50872	42 WCKHMS FNCY, CAN	A		2		
		50873	43 WCKHMS FNCY, CAN	A		2		
		50874	45 WCKHMS FNCY, CAN	A		2		
		50875	46 WCKHMS FNCY, CAN	A		2		
		50876	47 WCKHMS FNCY, CAN	A		2		
		50877	48 WCKHMS FNCY, CAN	A		2		
		50878	49 WCKHMS FNCY, CAN	A		2		
		50879	51 WCKHMS FNCY, CAN	A		2		
		50880	53 WCKHMS FNCY, CAN	A		2		
		50881	54 WCKHMS FNCY, CAN	A		2		
		50882	55 WCKHMS FNCY, CAN	A		2		
		50883	56 WCKHMS FNCY, CAN	A		2		
		50884	57 WCKHMS FNCY, CAN	A		2		
		50885	58 WCKHMS FNCY, CAN	A		2		
		50886	60 WCKHMS FNCY, CAN	A		2		
		50887	61 WCKHMS FNCY, CAN	A		2		
		50888	114 WNTRBRN DN, COLL	A		2		
		50889	2 WHRLNG DN, COLL	A		2		
		50890	4 WHRLNG DN, COLL	A		2		
		50891	5 WHRLNG DN, COLL	A		2		
		50892	6 WHRLNG DN, COLL	A		2		
		50893	7 WHRLNG DN, COLL	A		2		
		50894	8 WHRLNG DN, COLL	A		2		
		50895	10 WHRLNG DN, COLL	A		2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		50896	12 BLANCHARD RD, AV	A		3		
		50897	2 DEEPWOOD DR, AV	A		3		
		50898	8 DEEPWOOD DR, AV	A		3		
		50899	11 DEEPWOOD DR, AV	A		3		
		50900	14 DEEPWOOD DR, AV	A		3		
		50901	20 DEEPWOOD DR, AV	A	Y	3		
		50902	26 DEEPWOOD DR, AV	A		3		
		50903	33 DEEPWOOD DR, AV	A		3		
		50904	38 DEEPWOOD DR, AV	A		3		
		50905	53 DEEPWOOD DR, AV	A		3		
		50906	61 DEEPWOOD DR, AV	A		3		
		50907	67 DEEPWOOD DR, AV	A		3		
		50908	70 DEEPWOOD DR, AV	A		3		
		50909	73 DEEPWOOD DR, AV	A		3		
		50910	77 DEEPWOOD DR, AV	A		3		
		50911	78 DEEPWOOD DR, AV	A		3		
		50912	83 DEEPWOOD DR, AV	A		3		
		50913	93 DEEPWOOD DR, AV	A		3		
		50914	96 DEEPWOOD DR, AV	A		3		
		50915	104 DEEPWOOD DR, AV	A		3		
		50916	115 DEEPWOOD DR, AV	A		3		
		50917	118 DEEPWOOD DR, AV	A		3		
		50918	121 DEEPWOOD DR, AV	A		3		
		50919	126 DEEPWOOD DR, AV	A		3		
		50920	127 DEEPWOOD DR, AV	A		3		
		50921	130 DEEPWOOD DR, AV	A		3		
		50922	131 DEEPWOOD DR, AV	A		3		
		50923	137 DEEPWOOD DR, AV	A		3		
		50924	142 DEEPWOOD DR, AV	A		3		
		50925	143 DEEPWOOD DR, AV	A		3		
		50926	146 DEEPWOOD DR, AV	A		3		
		50927	147 DEEPWOOD DR, AV	A		3		
		50928	21 HCKLBRY HL, AV	A		3		
		50929	55 NEW RD, AV	A		3		
		50930	127 NEW RD, AV	A		3		
		50931	232 NEW RD, AV	A		3		
		50932	7 VERVILLE RD, AV	A		3		
		50933	41 ARCH ST, BLGTN	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		50934	49 ARCH ST, BLGTN	A		3		
		50935	5 COLONY RD, CAN	A		3		
		50936	6 COLONY RD, CAN	A		3		
		50937	13 COLONY RD, CAN	A		3		
		50938	15 COLONY RD, CAN	A		3		
		50939	16 COLONY RD, CAN	A		3		
		50940	20 COLONY RD, CAN	A		3		
		50941	21 COLONY RD, CAN	A		3		
		50942	23 COLONY RD, CAN	A		3		
		50943	25 COLONY RD, CAN	A		3		
		50944	26 COLONY RD, CAN	A		3		
		50945	27 COLONY RD, CAN	A		3		
		50946	29 COLONY RD, CAN	A		3		
		50947	7 DOWD AVE, CAN	A		3		
		50948	121 DOWD AVE, CAN	A		3		
		50949	129 DOWD AVE, CAN	A		3		
		50950	17 E HL RD, CAN	A		3		
		50951	19 E HL RD, CAN	A		3		
		50952	4 FOREST LN, CAN	A		3		
		50953	6 FOREST LN, CAN	A		3		
		50954	32 FOREST LN, CAN	A		3		
		50955	34 FOREST LN, CAN	A		3		
		50956	2 OLD CANTON RD, CAN	A		3		
		50957	6 CEMETERY RD, COLL	A		3		
		50958	16 COLLINS RD, COLL	A		3		
		50959	17 DYER AVE, COLL	A		3		
		50960	48 DYER AVE, COLL	A		3		
		50961	54 DYER AVE, COLL	A		3		
		50962	56 DYER AVE, COLL	A		3		
		50963	97 DYER AVE, COLL	A		3		
		50964	97A DYER AVE, COLL	A		3		
		50965	97B DYER AVE, COLL	A		3		
		50966	50 HIGH ST, COLL	A		3		
		50967	68 SIMONDS AVE, COLL	A		3		
		50968	79 SIMONDS AVE, COLL	A		3		
		50969	681SIMONDS AVE, COLL	A		3		
		50970	97 TRNGTN AV, COLL	A		3		
		50971	115B TRNGTN AV, COLL	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		50972	84A TRNGTN AV, COLL	A		3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT-FILTER PLANT	3	ENTRY POINT-FILTER P	A				
114	COLLINSVILLE WTP	3	ENTRY POINT - COLLIN	A				
		5	COMBINED FILTER EFFL	A				
2128	MDC BARKHAMSTED RESERVOIR	1	MDC BARKHAMSTED RESE	A				
2129	MDC NEPAUG RESERVOIR	1	NEPAUG RESERVOIR	A				
30019	MDC NEPAUG RESERVOIR	1	NEPAUG RES INTAKE	A				
37292	CTWC HUCKLEBERRY HILL TANK							
49477	CEMETARY ROAD PUMP STATION							
52174	WTP CLEARWELLS							
52176	WTP STANDPIPE							
58936	INTERCONNECTION - AVON WATER CO							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROBOTHAM, JR., PAUL C.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019
RUZBASAN, STEPHEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
PEIL, THEODORE W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
RUOT, DAVID A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2020

Water System Facility: COLLINSVILLE WTP (WSF ID: 114)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BARAL, JR, RAYMOND E.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2019
PRATT, STEPHEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
DESCHAMPS, WILLIAM A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
SMITH, MICHAEL J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2019
NELL, SCOTT	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
AUDET, JOSEPH R.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Certified Operator Information

Water System Facility: **COLLINSVILLE WTP (WSF ID: 114)**

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
NEGRELLI, SUSAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021 12/31/2020
ROGERS, SCOTT K.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	6/30/2019
RANDALL, DANIEL J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2020

Contact Information

Name				Organization			Job Title		
Mr. Craig J. Patla				Connecticut Water Company			Vp, Service Delivery		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
93 West Main Street						Clinton		CT	06413
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-664-6140						800-391-1924	cpatla@ctwater.com		

Contact Role(s): **Legal Contact**

Name				Organization			Job Title		
Mr. David Connors				Connecticut Water Company			Director, Service De		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
			93 West Main St			Clinton		CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-664-6141				860-227-4902	dconnors@ctwater.com				

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0231011	298-302 ALBANY TURNPIKE			C	28	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
298-302 ALBANY TURNPIKE			10				

Towns Served: CANTON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/10 - 12/31/18		Complete
	1/1/19 - 12/31/27		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/22	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #1 (3)	1/1/17 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0231011	298-302 ALBANY TURNPIKE			C	28	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
298-302 ALBANY TURNPIKE				10				

Towns Served: CANTON

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #1 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #1 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #1 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #1 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #1 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #1 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
CROSS CONNECTION EXEMPTION	3/1/2012	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
SUBMIT CCR TO THE DEPARTMENT	6/30/2013	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2013	
SUBMIT CCR TO THE DEPARTMENT	6/30/2016	
SUBMIT CCR CERTIFICATION FORM	8/9/2016	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2016	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0231011	298-302 ALBANY TURNPIKE			C	28	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
298-302 ALBANY TURNPIKE				10				
Towns Served: CANTON								

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2018	
SUBMIT CCR CERTIFICATION FORM	8/9/2018	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT-WELL #1	A				
1848	WELL #1	2	WELL #1	A				
44836	WELL 1 PRESSURE TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: **SMALL WATER SYSTEM**

Operator Name	Operator Type	Certification(s)	Certification Expiration
BEEMAN, ROBERT A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	12/31/2021
		WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021

Contact Information

Name		Organization		Job Title		
Mr. Matthew Schoenhardt		Watsul Associates, LLC		Manager		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
51 Westledge Road				West Simsbury	CT	06092
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-543-4005		860-543-4005	860-543-4005	860-543-4005	matthew.schoenhardt@raveis.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.